



Abrechnung Regelgrabenbreiten (Sohlbreite)

	Nennweite	Mediumrohr (Stahlrohr)		Mantelrohr	Achismaß mm	Grabenbreite mm	Mindestabst. M - mm	max. Überd. m
	DN	d_a - mm	s - mm	D_a - mm				
Serie III, 2 x verstärkt	25	33.7	3.2	125	275	1000	150	1.85
	32	42.4	3.2	140	290	1000	150	2.10
	40	48.3	3.2	140	290	1000	150	2.40
	50	60.3	3.2	160	360	1000	200	2.60
	65	76.1	3.2	180	380	1000	200	2.95
	80	88.9	3.2	200	400	1000	200	3.10
	100	114.3	3.6	250	450	1100	200	3.15
	125	139.7	3.6	280	580	1460	300	3.45
	150	168.3	4.0	315	615	1530	300	3.65
	200	219.1	4.5	400	800	2000	400	3.70
	250	273.0	5.0	500	900	2200	400	3.65
	300	323.9	5.6	560	1060	2620	500	3.85
	350	355.6	5.6	630	1130	2760	500	3.70
	400	406.4	6.3	670	1270	3140	600	3.95
	450	457.0	6.3	710	1310	3220	600	4.20
	500	508.0	6.3	800	1500	3700	700	4.10

VORABZUG
nur zur Kalkulation!

STADTWERKE TRAUNREUT

Phase:
AUSFÜHRUNGSPLANUNG

Plan Nr.:
-01-

FERNWÄRMENETZAUSBAU 2026
 REGELPLAN
 GRABENBREITEN

Maßstab:
ohne

Datum:
16.06.2026