


Heizung Vorlauf	Heizung Rücklauf	Dampf	Kondensat
Bestand Heizung Vorlauf	Bestand Heizung Rücklauf	Bestand Dampf	Bestand Kondensat
Demontage Heizung Vorlauf	Demontage Heizung Rücklauf	Demontage Dampf	Demontage Kondensat



I			
H			
G			
F			
E			
D			
C			
B			
A			
Index	Änderungen	Datum	Name

The image is a detailed architectural site plan of a building complex. A large, bold, red diagonal watermark is superimposed across the center, reading "VORABZUG Ausschreibung". The plan shows a rectangular building footprint with internal room divisions, including a central area with a staircase. The building is surrounded by a landscape featuring numerous circular symbols of varying sizes, representing trees or landscaping. To the left of the main building, there is a smaller, more complex structure. The entire site is enclosed within a boundary line, with various dimensions and labels (e.g., 10m, 15m, 20m) indicating distances and areas. A north arrow is located in the bottom left corner.

Heizung		PLANNR. 2001 SGP_H2O_H2S_H202_001_x_260914		 Potthoff Ihr bauseitiges Gesundheitsunternehmen
BESTELLT Han/CorMe	DATUM 06.10.2016	BEZUGS-PROJEKTATION SGP_ARC_Grundrisse Index 0-2 : 24.04.26		
GEZEHRT 	DATUM 	BEZUGS-GLIEDERUNG 		
NOTIZEN <i>J.</i>	INDEX -	BEZUGS-PROJEKTION 		

Werkdatum: 06.10.2026 \\W-FER03-SQL\planca\Projekte\2063_5420_HZG\BP_HZG_FS.n4m

HK	Bezeichnung	DN	Leistung in kW	Gleich- zeitigkeit	tv in °C	tr in °C	m in kg/h
E	Einspeisung Wärmeversorgung	65	183	1,0	45	30	10.519
1	RLT-Erhitzer 3.OG / Dach	65	92	1,0	40	30	7.898
2	stat. Heizung Fußbodenheizung	65	91	1,0	37	32	15.861

Nr.	DN	PN	kvs	dp Ventil in kPa	Art
V1	40	6	25	10	3-Wegemischer
V2	50	6	40	15,7	3-Wegemischer
V3	40	6	25	10	3-Wegemischer

Nr.	V in m ³ /h	H in mbar
P1	7,9	1210
P2	7,3	920
P3	7,9	530

Nr.	V in m³/h	Qn in m³/h	DN
Z1	10,9	15	50
Z2	-	-	-
Z3	-	-	-
Z4	-	-	-

Erdgeschoss - Heizungszentrale 10.0.21

