

Technical drawing of a sludge pump station layout, showing dimensions and component labels.

Dimensions (m):

- Overall width: 7,35
- Left offset: 30
- Right offset: 30
- Horizontal distance between pump centers: 6,75
- Vertical distance from base to pump center: 62
- Vertical distance from base to pump center: 20
- Horizontal distance from left wall to pump center: 1,22
- Horizontal distance between pump centers: 1,7
- Horizontal distance from pump center to right wall: 1,91
- Horizontal distance from pump center to right wall: 1,7
- Horizontal distance from pump center to right wall: 3,28
- Overall width: 6,75

Labels and Notes:

- 1.2
- 1.3
- SCHLAMMDRUCKLEITUNG DN 125 / Werkst.: 1.4571
- SCHLAMMSAUGLEITUNG DN 125 / Werkst.: 1.4571
- Ok.-FFB: +126,06
- Gel.: +125,96
- BESTEHENDE ÜS-SCHLAMMLEITUNG vom Schlammilo zur Eindickmaschine
- +128,48

Technical drawing of a sludge pump station (Schlammstation) showing a side elevation. The drawing includes dimensions for overall length (4,00m), individual components (1,34m, 1,43m, 1,23m), and heights (+125,88, +126,06, +126,00, +128,48). It details the sludge pressure line (Schlammdruckleitung DN 125 / Werkst.: 1.4571) and the sludge discharge line (Schlammsaugleitung DN 125 / Werkst.: 1.4571). Key components labeled include pumps (1.2, 1.3), valves (1.1, 1.4), and a wall penetration (Wanddurchführung). The drawing also shows the existing sludge line from the silo to the dewatering machine (Bestehende ÜS-Schlammleitung vom Schlamm-silo zur Eindickmaschine).

[illegible]

 Geplante Maßnahmen
 Pflasterbelag - Bestand
 Grünfläche

- # 1. SCHLAMPUMPWERK
- 1.1 FESTSTOFFMESSUNG
 - 1.2 ZERKLEINER MIT SCHWERGUTABSCHIEDER
 - 1.3 PUMPEN
 - 1.4 MENGENMESSUNG
 - 1.5 SCHALT- UND STEUERANLAGE

Nicht für die Ausführung freigegeben!

Bearb.:	Datum:		Maßstab: o.M.
Gez.:	Pr. Nr.: 22334		
Gepr.:	Anl. Nr.:		

Kampfmittelfreigabe:
Vor Baubeginn von sämtlichen erdeingreifenden Arbeiten ist eine schriftliche Kampfmittelfreigabe durch den Bauherrn vorzulegen.

Der Inhalt dieser Planunterlage ist gemäß
DIN ISO 16016 urheberrechtlich geschützt.